

Interpreting Well Water Quality Results for common metals and minerals

INDIVIDUAL TESTS:	PAGE
Arsenic Screen	1
Calcium	2
Copper	2
Iron	2
Lead	2
Magnesium	3
Manganese	3
Potassium	3
Sodium	3
Sulfate	4
Zinc	4

Using this fact sheet

This fact sheet is intended to help you interpret the results of the metals package:



Some of these tests are important because they deal with health-related contaminants




Other tests will tell you about important aesthetic concerns associated with water (i.e. taste, color, and/or odor)



Others may be beneficial metals or minerals that may be found in well water

Interpreting your numbers:



No considerations



Aesthetic concerns are possible



Health standard or health advisory level

Arsenic Screen

Arsenic is a naturally occurring element that can be released from soils or other geologic material that groundwater contacts. Water less than 0.010 mg/L is considered safe for consumption.

When concentrations are greater than 0.010 mg/L, steps should be taken to reduce arsenic in drinking water because of concerns that long-term consumption of water with this level of arsenic may increase the risk of certain types of cancers. There are additional concerns when water contains greater than 0.100 mg/L (100 ppb) arsenic.



Less than 0.005* 0.010

0.100 mg/L

If arsenic concentrations are greater than 0.010 mg/L:

Consider testing for arsenic again using a low-level arsenic analysis. This will provide a more accurate reading and confirm whether additional steps should be taken. If low-level arsenic test confirms greater than 0.010 mg/L of arsenic, avoid using water for drinking and cooking.

Water treatment such as reverse osmosis systems or distillation have been shown to be effective for reducing arsenic levels.

***Limit of Detection (LOD):**

The lowest metal or mineral concentration likely to be reliably distinguished from a sample blank and at which detection is feasible.

Concentrations below the LOD are reported as "Less than" the value at which the analytical equipment used to measure your sample is capable of detecting.

Calcium

Calcium is an essential nutrient and is considered beneficial to bone/tooth development, blood clotting, and may also reduce heart disease; though the amount found in water is generally a small portion of calcium compared to what we get from a healthy diet. Naturally occurring in water as a result of groundwater dissolving calcium from soils or rocks such as dolomite or limestone. Calcium contributes to the formation of scale. Typical values for Wisconsin generally range between 9 and 67 mg/L of calcium in unsoftened well water.

Copper

Not naturally occurring at significant concentrations in groundwater; copper can be found at elevated levels when naturally corrosive water contacts copper plumbing. Bluish-green staining of sinks or toilet tanks is an indication of copper corrosion. Levels less than 1.300 are considered safe for drinking water. Levels above 1.300 mg/L in drinking water can result in digestive issues (ex. upset stomach, nausea, diarrhea) for some individuals.

If copper levels are greater than 1.300 mg/L:

Elevated copper is most evident in water that sits in plumbing for an extended period. Allowing the water to run for 1-2 minutes prior to using water for drinking and cooking will significantly reduce your exposure to copper.



Less than 0.001* 0.500 1.300 mg/L

Iron

Iron is a naturally occurring mineral found in soils and rocks that store groundwater; it is a common aesthetic complaint for many well owners. Concentrations of iron above 0.3 mg/L may result in taste issues and/or result in reddish-brown staining of sinks, showers and toilets. Low levels of iron can be removed by a water softener. Amounts greater than 1.0 mg/L may require treatment specifically designed for iron removal.



Less than 0.008* 0.300 1.000 mg/L

Lead

Elevated lead can occur when water contacts brass fixtures, lead pipes or lead solder. The health-related drinking water standard for lead is 0.015 mg/L. In children, lead exposure has been linked to damage to the central and peripheral nervous system, learning disabilities, shorter stature, impaired hearing, and impaired formation and function of blood cells. There are no known benefits to lead in the human body; therefore, everyone should reduce exposure to lead.

If you have elevated lead, brass fixtures, lead pipes or lead solder in your plumbing system:

Run your water for 1-2 minutes prior to use for drinking/cooking in order to flush water with high lead levels from your water system. Corrosive water is more likely to result in elevated lead. Point-of-use treatment devices (ex. pitcher type or faucet mounted filters) can also reduce lead in drinking water.



Less than 0.004* 0.015 mg/L

Magnesium

Naturally occurring in water as a result of groundwater dissolving magnesium from soils or dolomite rock. Magnesium is an essential nutrient and is considered beneficial to health, although the amount found in water is generally a small portion of magnesium compared to what we get from a healthy diet. Magnesium is related to hardness and can contribute to the formation of scale when found at high concentrations. Typical values for Wisconsin generally range between 3 and 35 mg/L of magnesium in unsoftened well water.

Manganese

Manganese is a naturally occurring mineral found in soils and rocks that groundwater is stored and moves through. Concentrations of manganese above 0.050 mg/L may result in taste issues and/or result in black staining of sinks, showers and toilets.

The health advisory level for manganese is 0.300 mg/L. Drinking water with greater than 0.300 mg/L over many years may harm the nervous system. Manganese can be reduced using appropriate treatment.



Potassium


Naturally occurring at concentrations less than 5 mg/L. Potassium is beneficial to health, however the amount found in water is not a significant source of potassium compared to a healthy diet. If water softener uses potassium chloride softener salt, concentrations will be significantly greater than 5 mg/L.

Sodium

Sodium is naturally found in Wisconsin's groundwater at levels less than 5 mg/L. It is not a significant health concern for most people. For individuals on prescribed no salt diets, the American Health Association and US EPA recommend less than 20 mg/L in drinking water. Water with greater than 60 mg/L of sodium may have a salty taste associated with it.

When sodium levels exceed calcium and magnesium levels, it suggests that water is softened or partially softened. Sodium may be elevated in areas where groundwater is impacted by septic system effluent or nearby road salt use. If sodium was elevated from one of these two sources, chloride levels would likely be elevated as well.

People often prefer the taste of calcium and magnesium in unsoftened water versus softened water that contains sodium. As a result, water softeners often bypass the cold-water kitchen faucet.



Information about Drinking Water Standards:

Interpreting your results section is based on the U.S. Environmental Protection Agency's (EPA) Maximum Contaminant Levels (MCL) for public drinking water supplies.

Levels considered safe for long-term consumption are below the MCL or the Health Advisory Level.

Aesthetic limits are taken from the Secondary Drinking Water regulations for public water systems and are based on the potential to influence taste, color, and/or odor of the water.

Drinking water standards are not enforceable for private wells, however the standards may be useful in helping homeowners decide if corrective measures are needed.

Sulfate

Naturally occurring in groundwater at low levels, generally less than 25 mg/L. High levels of sulfate occur naturally in some groundwater aquifers in eastern Wisconsin and portions of Northern Wisconsin near Lake Superior. Excessive water hardness (calcium and magnesium) is common in water that contains significant sulfate.

Concentrations over 250 mg/L may give water an off taste and may induce a laxative type effect (diarrhea like symptoms) in persons not accustomed to consuming water with high levels of sulfate. Water with greater than 500 mg/L sulfate may reduce milk production in dairy cows.



When measuring concentrations of metals and minerals in water:

1 milligram per liter (mg/L) = 1 part per million (ppm)

1 microgram per liter (ug/L) = 1 part per billion (ppb)

and

1 ppm = 1,000 ppb

Zinc

Normally less than 1 mg/L in Wisconsin groundwater. Concentrations greater than 1 mg/L usually occur when corrosive water is distributed through galvanized pipes. There is a health advisory level of 2 mg/L, too much zinc can cause stomach cramps, nausea and vomiting. There is an aesthetic limit of 5 mg/L; water containing more than 5 mg/L may have a chalky appearance and metallic or astringent taste.

If water contains greater than 2 mg/L of zinc:

Concentrations of zinc are likely to be greatest in water that sits in the plumbing system for extended periods of time. If zinc is elevated, letting the water run for 1-2 minutes prior to use should significantly reduce concentrations.



Additional information:

Wisconsin Well Water Quality Viewer – Search online for “WI Well Water Viewer UWSP”
Search for well water quality in your community using this interactive mapping tool.

What’s Wrong with My Water? - Search online for “WDNR What’s wrong with my water”
Diagnose taste, color, and odor problems and solutions using this resource from the Wisconsin Department of Natural Resources.

Drinking Water Concerns – Search online for “Drinking water concerns – Wisconsin Department of Health Services” – Additional information on some of the metals and minerals discussed in this brochure as well as others that may be important to test for.

Center for Watershed Science and Education

Water and Environmental Analysis Lab

Trainer Natural Resources Building
800 Reserve St.
Stevens Point, WI 54481

Phone: 715-346-4270
E-mail: weal@uwsp.edu

www.uwsp.edu/cnr-ap/watershed

April 2020



Center for Watershed Science and Education
College of Natural Resources
University of Wisconsin - Stevens Point



Extension
UNIVERSITY OF WISCONSIN-MADISON